Main switch, P3, 100 A, surface mounting, 3 pole + N, STOP function, With black rotary handle and locking ring, Lockable in the 0 (Off) position



Part no. P3-100/I5/SVB-SW/N 207376

General specifications	
Product name	Eaton Moeller® series P3 Main switch
Part no.	P3-100/I5/SVB-SW/N
EAN	4015082073763
Product Length/Depth	169 millimetre
Product height	280 millimetre
Product width	200 millimetre
Product weight	1.53 kilogram
Certifications Product Tradenome	CSA Class No.: 3211-05 UL 60947-4-1 IEC/EN 60204 UL CSA-C22.2 No. 94 UL Category Control No.: NLRV VDE 0660 CSA CSA-C22.2 No. 60947-4-1-14 CSA File No.: 012528 UL File No.: E36332 IEC/EN 60947-3 IEC/EN 60947 CE
Product Tradename	P3
Product Type	Main switch
Product Sub Type	None
Catalog Notes	Rated Short-time Withstand Current (Icw) for a time of 1 second
eatures & Functions	
Features	Version as main switch Version as maintenance-/service switch
Fitted with:	Black rotary handle and locking ring
Functions	STOP function Interlockable
Locking facility	Lockable in the 0 (Off) position
Number of poles	4
General information	
Accessories	Auxiliary contact fitted by user.
Degree of protection	NEMA 12
Degree of protection (front side)	IP65
Lifespan, mechanical	100,000 Operations
Mounting method	Surface mounting
Mounting position	As required
Operating frequency	1200 Operations/h
Overvoltage category	III
Pollution degree	3
Rated impulse withstand voltage (Uimp)	6000 V AC
Safe isolation	440 V AC, Between the contacts, According to EN 61140
Safety parameter (EN ISO 13849-1)	B10d values as per EN ISO 13849-1, table C.1
Shock resistance	15 g, Mechanical, According to IEC/EN 60068-2-27, Half-sinusoidal shock 20 ms
Suitable for	Ground mounting Branch circuits, suitable as motor disconnect, (UL/CSA)
Switching angle	90 °
Climatic environmental conditions	
Ambient operating temperature - min	-25 °C
Ambient operating temperature - max	40 °C

Ambient operating temperature (enclosed) - min	-25 °C
Ambient operating temperature (enclosed) - max	40 °C
Climatic proofing	Damp heat, cyclic, to IEC 60068-2-30
omnedo proomig	Damp heat, constant, to IEC 60068-2-78
Terminal capacities	
Terminal capacity	1 x (1.5 - 25) mm², flexible with ferrules to DIN 46228 2 x (1.5 - 6) mm², flexible with ferrules to DIN 46228 1 x (2.5 - 35) mm², solid or stranded 2 x (2.5 - 10) mm², solid or stranded 14 - 2 AWG, solid or flexible with ferrule
Screw size	M5, Terminal screw
Tightening torque	3 Nm, Screw terminals 26.5 lb-in, Screw terminals
Electrical rating	
Rated breaking capacity at 220/230 V (cos phi to IEC 60947-3)	760 A
Rated breaking capacity at 400/415 V (cos phi to IEC 60947-3)	740 A
Rated breaking capacity at 500 V (cos phi to IEC 60947-3)	880 A
Rated breaking capacity at 660/690 V (cos phi to IEC 60947-3)	520 A
Rated operational current (Ie) at AC-3, 220 V, 230 V, 240 V	71 A
Rated operational current (Ie) at AC-3, 380 V, 400 V, 415 V	71 A
Rated operational current (le) at AC-3, 500 V	65 A
Rated operational current (Ie) at AC-3, 660 V, 690 V	23.8 A
Rated operational current (le) at AC-21, 440 V	100 A
Rated operational current (Ie) at AC-23A, 230 V	100 A
Rated operational current (Ie) at AC-23A, 400 V, 415 V	100 A
Rated operational current (le) at AC-23A, 500 V	96 A
Rated operational current (le) at AC-23A, 690 V	68 A
Rated operational current (le) at DC-1, load-break switches I/r = 1 ms	100 A
Rated operational current (Ie) at DC-23A, 24 V	50 A
Rated operational current (Ie) at DC-23A, 48 V	50 A
Rated operational current (Ie) at DC-23A, 60 V	50 A
Rated operational current (Ie) at DC-23A, 120 V	25 A
Rated operational power at AC-3, 380/400 V, 50 Hz	37 kW
Rated operational power at AC-3, 415 V, 50 Hz	37 kW
Rated operational power at AC-3, 510 V, 50 Hz	45 kW
Rated operational power at AC-33, 690 V, 50 Hz	37 kW
Rated operational power at AC-23A, 220/230 V, 50 Hz	30 kW
Rated operational power at AC-23A, 400 V, 50 Hz	55 kW
Rated operational power at AC-23A, 500 V, 50 Hz	55 kW
Rated operational power at AC-23A, 690 V, 50 Hz	55 kW
Rated operational voltage (Ue) at AC - max	690 V
Rated uninterrupted current (Iu)	100 A
Uninterrupted current	Rated uninterrupted current lu is specified for max. cross-section.
Short-circuit rating	
Rated conditional short-circuit current (Iq)	4 kA (Load side) 80 kA (Supply side)
Rated short-time withstand current (Icw)	2 kA
Short-circuit current rating (basic rating)	10 kA, SCCR (UL/CSA) 150A, max. Fuse, SCCR (UL/CSA)
Short-circuit protection rating	100 A gG/gL, Fuse, Contacts
Switching capacity	
Load rating	1.6 x l# (with intermittent operation class 12, 40 % duty factor) 1.3 x l# (with intermittent operation class 12, 60 % duty factor) 2 x l# (with intermittent operation class 12, 25 % duty factor)
Number of contacts in series at DC-23A, 24 V	1
Number of contacts in series at DC-23A, 48 V	2
Number of contacts in series at DC-23A, 60 V	2
Number of contacts in series at DC-23A, 120 V	3
Switching capacity (main contacts, general use)	90 A, Rated uninterrupted current max. (UL/CSA)

Security or Security	Switching capacity (auxiliary contacts, general use)	10A, IU, (UL/CSA)
ABOUT CASI Valega per context pair in sarias. Motor ratios Assigned motor power at 115/120 V.08 Hr.1 phane Assigned motor power at 105/120 V.08 Hr.2 phane Assigned motor power at 2002 V.W. Hr.1 phane Assigned motor power at 2002 V.W. Hr		
Walsage ner contact pair in series Whoter critis Assigned matrix power at 119/120 V 69 Hz. Fightase Assigned matrix power at 2002/08 V 16 Hz. Fightase Assigned matrix power at 2002/08 V 16 Hz. Fightase Assigned matrix power at 2002/08 V 16 Hz. Fightase Assigned matrix power at 2002/08 V 16 Hz. Fightase Assigned matrix power at 2002/08 V 16 Hz. Fightase Assigned matrix power at 2002/08 V 16 Hz. Fightase Assigned matrix power at 2002/08 V 16 Hz. Fightase Assigned matrix power at 2002/08 V 16 Hz. Fightase Assigned matrix power at 2002/08 V 16 Hz. Fightase Assigned matrix power at 2002/08 V 16 Hz. Fightase Assigned matrix power at 2002/08 V 16 Hz. Fightase Assigned matrix power at 2002/08 V 16 Hz. Fightase Assigned matrix power at 2002/08 V 16 Hz. Fightase Control circuit reliability Number of assignity cantacts (change-over contracts) Number of assignity contracts (control circuit reliability) Actuator Designity verification Equipment of assignity control dependent Pod First dissipation appealsh Polas First dissipation per polic, current-dependent Pod First dissipation per polic, per policy per		A600 (UL/CSA)
Assigned motor power at 119/120 V, 58 Hz, 1-phase 5 PP Assigned motor power at 2002/08 V, 68 Hz, 1-phase 10 PP Assigned motor power at 2002/08 V, 68 Hz, 1-phase 11 PP Assigned motor power at 2002/08 V, 68 Hz, 1-phase 11 PP Assigned motor power at 2002/08 V, 68 Hz, 1-phase 11 PP Assigned motor power at 2002/08 V, 68 Hz, 2-phase 2 PH Assigned motor power at 2002/08 V, 68 Hz, 2-phase 2 PH Assigned motor power at 2002/08 V, 68 Hz, 2-phase 2 PH Assigned motor power at 2002/08 V, 68 Hz, 2-phase 2 PH Assigned motor power at 4004/08 V, 68 Hz, 2-phase 2 Ph Assigned motor power at 4004/08 V, 68 Hz, 2-phase 2 Ph Actuator volume at 4004/08 V, 68 Hz, 2-phase 2 Ph Actuator volume at 4004/08 V, 68 Hz, 2-phase 2 Ph Actuator volume at 4004/08 V, 68 Hz, 2-phase 2 Ph Actuator volume at 4004/08 V, 68 Hz, 2-ph		
Assigned motor power at 115/120 V, 50 Hz, 1-phase 10 HP Assigned motor power at 2000 W, 50 Hz, 1-phase 10 HP Assigned motor power at 2000 W, 50 Hz, 1-phase 20 HP Assigned motor power at 2000 W, 50 Hz, 3-phase 20 HP Assigned motor power at 2000 W, 50 Hz, 3-phase 20 HP Assigned motor power at 2000 W, 50 Hz, 3-phase 20 HP Assigned motor power at 2000 W, 50 Hz, 3-phase 20 HP Assigned motor power at 2000 W, 50 Hz, 3-phase 20 HP Assigned motor power at 2000 W, 50 Hz, 3-phase 20 HP Assigned motor power at 2000 W, 50 Hz, 3-phase 20 HP Assigned motor power at 2000 W, 50 Hz, 3-phase 20 HP Assigned motor power at 2000 W, 50 Hz, 3-phase 20 HP Assigned motor power at 2000 W, 50 Hz, 3-phase 20 HP Assigned motor power at 2000 W, 50 Hz, 3-phase 20 HP Assigned motor power at 2000 W, 50 Hz, 3-phase 20 HP Assigned motor power at 2000 W, 50 Hz, 3-phase 20 HZ Assigned motor power at 2000		60 V
Assigned motor power at 200/200 V. 50 Pt., 1-phase Assigned motor power at 200/200 V. 50 Pt., 2 phase 20 PP Assigned motor power at 200/200 V. 50 Pt., 3 phase Assigned motor power at 200/200 V. 50 Pt., 3 phase Assigned motor power at 200/200 V. 50 Pt., 3 phase Assigned motor power at 200/200 V. 50 Pt., 3 phase Assigned motor power at 200/200 V. 50 Pt., 3 phase Assigned motor power at 200/200 V. 50 Pt., 3 phase Contacts Contract circia mislatility I failure per 100/000 ewitching operature statistically determined, at 24 V DC, 10 Pt. Number of auxiliary contacts informally closed contacts) Number of auxiliary contacts informally open contacts O Contracts Contracts informally open contacts O Contracts Contracts informally open contacts O Contracts Contra	Motor rating	
Assigned motor power at 2010-208 V. 60 Hz. 3 sphase Assigned motor power at 2010-208 V. 60 Hz. 1 sphase Assigned motor power at 2010-208 V. 60 Hz. 1 sphase Assigned motor power at 2010-208 V. 60 Hz. 3 sphase Assigned motor power at 4010-408 V. 60 Hz. 3 phase Assigned motor power at 5010-608 V. 60 Hz. 3 phase Assigned motor power at 5010-608 V. 60 Hz. 3 phase Assigned motor power at 5010-608 V. 60 Hz. 3 phase Assigned motor power at 5010-608 V. 60 Hz. 3 phase Contracts Control circuit reliability Number of auxiliary contracts (change-over contracts) Actuator Actuator Actuator type Design verification Equipment hast dissipation, current dependent Priod Heat dissipation capacity Prios Heat dissipation capacity	Assigned motor power at 115/120 V, 60 Hz, 1-phase	5 HP
Assigned motor power at 220/20 V, 50 Hz. 1-shase Assigned motor power at 220/20 V, 50 Hz. 3-shase 25 HP Assigned motor power at 20/20 V, 50 Hz. 3-shase 50 HP Assigned motor power at 57/500 V, 50 Hz. 3-shase 75 HP Contracts Control circuit reliability 1 failure per 100,000 evoliching operations statistically determined, at 24 V DC, 10 m/sl Mumber of auxiliary contacts (brange-over contacts) 0 Number of auxiliary contacts (brange-over contacts) 0 Number of auxiliary contacts (brange-over contacts) 0 Actuation Actuation Actuation Black Actuation color Actuation Actuation Actuation Black Actuation color Actuation Actuation Actuation Black Actuation specific Actuation Black Actuation specific Promally open contacts) 7.5 W Heat dissipation, current-dependent Pvid Heat dissipation, current-dependent Pvid Heat dissipation, non-current dependent Pvid Heat dissipation non-current dependent Pvid Heat dissipation non-current dependent Pvid 10.2 A Composition expansity Pfilias Weets the product standard is requirements. 10.2.3.1 Verification of institution of ins	Assigned motor power at 200/208 V, 60 Hz, 1-phase	10 HP
Assigned motor power at 200/240 V, 60 Hz, 3-phase Assigned motor power at 400/240 V, 60 Hz, 3-phase Assigned motor power at 400/240 V, 60 Hz, 3-phase Assigned motor power at 400/240 V, 60 Hz, 3-phase Contacts Coerrol circuit reliability Number of auxiliary contacts (charge over contacts) Number of auxiliary contacts (charge over contacts) Number of auxiliary contacts (normally closed contacts) Number of auxiliary contacts (normally closed contacts) Number of auxiliary contacts (normally closed contacts) Number of auxiliary contacts (normally upon contacts) Actuator Actuator rype Doc coupling rotary drive Design verification Equipment heat dissipation, current-dependent Pvid Peter designation, current-dependent Pvid Peter designation coprolly Prices Do V Peter designation, current-dependent Pvid Peter designation of the current-dependent Pvid Peter designation of current for specified heat dissipation (not put to specified heat dissipation) Peter designation of the current-dependent Pvid Peter designation of current for specified heat dissipation (not put to specified heat dissipation) Peter designation of the current-dependent Pvid Peter designation of resistance of insulation materials to normal heat Peter designation of the current-dependent Pvid Peter designation of the current-depende	Assigned motor power at 200/208 V, 60 Hz, 3-phase	20 HP
Assigned motor power at \$95,400 V, 60 Hz, 3-phase Assigned motor power at \$95,400 V, 60 Hz, 3-phase Control Circuit reliability Number of auxiliary contacts (change-ever contacts) Actuator color Actuator color Actuator vpp Door coupling rotary drive Design verification Equipment heat dissipation, current-dependent Prid Heat dissipation capacity Pridics Heat dissipation per pole, current-dependent Prid Heat dissipation capacity Pridics Next operational current for specified heat dissipation (In) 100 A Static heat dissipation, non-current-dependent Prid 102 Correion resistance Meets the product standard's requirements. 102.31 Verification of hermal stability of enclosures Meets the product standard's requirements. 102.32 Verification of resistance of insulating materials is normal heat Meets the product standard's requirements. 102.33 Instruction of hermal stability of enclosures Meets the product standard's requirements. 102.32 Proximication of resistance of insulating materials is normal heat Meets the product standard's requirements. 102.32 Resistance of insulating materials in normal heat 102.32 Resistance of insulating materials in normal heat 102.32 Resistance of insulating materials 103.32 Degree of protection of assemblies 104.55 Protection against electric shield. 105.51 Protection against electric shield. 106.61 Incorporation of overlapping distances 107.71 Internal electrical circuits and connections 108.52 Protection against electric shield. 109.54 Teasing and electrical circuits and connections 109.54 Teasing and electrical circuits and connections 109.55 Protection against electric shield. 109.65 Incorpo	Assigned motor power at 230/240 V, 60 Hz, 1-phase	15 HP
Assigned motor power at 579,000 V, 60 Hz, 3-phases Central circuit reliability Number of auxiliary contacts (change-over contacts) Number of auxiliary contacts (change-over contacts) Number of auxiliary contacts (normally closed contacts) Number of auxiliary contacts (normally closed contacts) Number of auxiliary contacts (normally egen contacts) Number of auxiliary contacts (normally egen contacts) Actuator Actuator Actuator Actuator Black Actuator type Doer coupling rotary drive Doer coupling rotary drive Design verification Equipment heat dissipation, capacity Prizes Near dissipation capacity Prizes Near dissipation oper pole, current-dependent Prid 17.5 W Heat dissipation oper pole, current-dependent Prid 18.8 Actuator type Doer coupling rotary drive Near dissipation oper pole, current-dependent Prid 19.2 A Ward dissipation oper pole, current-dependent Prid 19.2 A Ward dissipation oper pole, current-dependent Prid 19.2 A Ward dissipation oper pole, current-dependent Prid 19.2 A Varification of existence of invaliding natorials to normal heat 19.2 A Varification of thermal stability of enclosures 19.2 A Resistance to other aviolet (UV) radiation 19.2 A Resistance to other aviolet (UV) radiation 19.2 A Resistance to other aviolet (UV) radiation 19.2 Beckmania limpact 19.2 A Resistance to other aviolet (UV) radiation 19.2 Beckmania limpact 19.2 A Resistance to other aviolet (UV) radiation 19.2 Deservation of assistance of invaliding natorials to normal heat 19.2 Protection against electric shock 19.2 None not apply, since the entire witchepar exeeds to be evaluated. 19.2 Protection against electric shock 19.2 Protection against electric shock 19.3 Protection against electric strength 19.4 Clearances and creepage distances 19.5 Protection against electric strength 19.6 Commences for exercise exercise service and components 19.7 Internal electric at foolowers and components 19.8 Residuated of requirements. 19.9 Protection against electric strength 19.1 Internal el	Assigned motor power at 230/240 V, 60 Hz, 3-phase	25 HP
Control circuit reliability All failure per 100,000 switching operations statistically determined, at 24 V DC, 10 mAI Number of auxiliary contracts (normally closed contacts) Description of auxiliary contracts (normally closed contacts) Actuator color Actuator type Door coupling rotary drive Black Actuator type Door coupling rotary drive Beginnent head dissipation, current-dependent Pvid Feature dissipation capacity Pdiss Head dissipation or probe. current-dependent Pvid Feature dissipation capacity Pdiss Head dissipation on probe. current-dependent Pvid 7.5 W Head dissipation on probe. current-dependent Pvid 10.0 A Statis heat dissipation non-current-dependent Pvid 10.2 Corrosion resistance Meass the product standard's requirements. Meass the product standard's requirements. 10.2.3 Verification of thermal stability of enclosures Meass the product standard's requirements. 10.2.3 Verification of resistance of insulating materials to normal heat 10.2.3 Verification of insulating materials to normal heat 10.2.4 Statistication of resistance of insulating materials to normal heat 10.2.5 Uffining Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Infining Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Infining Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Corrosion of switchings devices and components 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.5 Intimate lederal circuits and communications 10.5 Internal electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Temperature rise 10.6 Temperature rise Product standard's requirements. 10.8 Temperature rise 10.9 Temperature rise 10.9 Temperature rise Product standard's requirements. 10.9 Temperature rise 10.9 Temperature	Assigned motor power at 460/480 V, 60 Hz, 3-phase	60 HP
Control circuit reliability I failure per 100,000 switching operations statistically determined, at 24 V DC, 10 nn(A) Number of auxiliary contacts (change-over contacts) O Wumber of auxiliary contacts (normally open contacts) Actuator Actuator Actuator volv Actuator type Design verification Equipment head dissipation, current-dependent Pvid Head dissipation capacity Poiss O W Head dissipation capacity Poiss O W Head dissipation oper pole, current-dependent Pvid Placed operational current for specified head dissipation (in) Static head dissipation, on-current-dependent Pvid 10.2 Corresion resistance Meats the product standard's requirements. 10.2.3 Product of thermal stability of enclosures 10.2.3 Product of resistance of insulating materials to normal heat 10.2.4 Switchina of resistance of insulating materials to normal heat 10.2.5 Uffing Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Incorporation of switching devices and components 10.2 Does not apply, since the entire switchgear needs to be evaluated. 10.2 Incorporation of switching devices and components 10.2 Recipions Ments the product standard's requirements. 10.3 Dependency electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.4 Decarances and creepage distances Ments the product standard's requirements. 10.5 Protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Does not apply, since the entire switchgear needs to be evaluated. 10.8 Incorporation of switching devices and components 10.9 Does not apply, since the entire switchgear needs to be evaluated. 10.1 Incorporation of switching devices and components 10.3 Imperial electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.	Assigned motor power at 575/600 V, 60 Hz, 3-phase	75 HP
Number of auxiliary contacts (change-over contacts) Number of auxiliary contacts (normally closed contacts) Number of auxiliary contacts (normally open contacts) Actuator Actuator S Actuator S Actuator yes Door coupling rotary drive Door coupling rotary drive Dosign verification Equipment heat dissipation, current-dependent Pvid DV Reat dissipation capacity Pdiss Reat dissipation capacity Pdiss Reat dissipation current for specified heat dissipation (In) Reat dissipation current for specified heat for specified heat for sequence heat current for specified heat dissipation (In) Reat the product standard's requirements. Rest the product standard's requirements. Reat the product standard's requirements. Reat the product	Contacts	
Number of auxiliary contacts (normally closed contacts) Number of auxiliary contacts (normally apen contacts) Actuator olor Actuator type Design verification Equipment heat dissipation, current-dependent Pvid Read operational current for specified heat dissipation (play size of the dissipation) Static heat dissipation, uncerturent dependent Pvid Read operational current for specified heat dissipation (play size of the dissipation) Static heat dissipation, uncerturent dependent Pvid Read operational current for specified heat dissipation (play size of the dissipation) Static heat dissipation, uncerturent dependent Pvid Read operational current for specified heat dissipation (play size of the dissipation) Static heat dissipation, uncerturent dependent Pvs 102.23 I Verification of thermal stability of enclosures 102.23 I Verification of thermal stability of enclosures 102.23 I Verification of resistance of insulating materials to normal heat 102.23 Resist of insult materials to abnormal heat/fire by internal elect effects 102.24 Resistance to ultra-violet (UV) radiation 102.25 Lifting Does not apply, since the entire svirtchgear needs to be evaluated. 102.26 Internation of swirtching devices and components 102.27 Internal electric all circuits and compendents 102.48 Degree of protection of assemblies Does not apply, since the entire svirtchgear needs to be evaluated. 102.49 Internal electric stock Does not apply, since the entire svirtchgear needs to be evaluated. 102.50 Internal electric stock and components 103.60 Incorporation of swirtching devices and components 104.61 Incorporation of swirtching devices and components 105.71 Internal electric is circuits and connections 106.72 Internal electric is circuits and connections 107.73 Internal electric is circuits and connections 108.74 Internal electric is circuits and connections 109.75 Internal electric is circuits and connections 109.75 Internal electric is circuits and connections 109.75 Internal electric is circuits and con	Control circuit reliability	
Number of auxiliary contacts (normally open contacts) Actuator Actuator color Actuator color Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation apacity Pdiss Heat dissipation per pole, current-dependent Pvid Astudor ryne Heat dissipation per pole, current-dependent Pvid Static heat dissipation current of specified heat dissipation (In) Static heat dissipation of per pole, current-dependent Pvid Astudo pravational current for specified heat dissipation (In) Static heat dissipation non-current dependent Pvid Moets the product standard's requirements. 102.21 Verification of thermal stability of enclosures Meets the product standard's requirements. 102.32 Verification of resistance of insulating materials to normal heat Moets the product standard's requirements. 102.33 Resist, of insul. mat, to abnormal heat/fire by internal elect. effects Moets the product standard's requirements. 102.4 Resistance to ultra-violet (IV) radiation UV resistance only in connection with protective shield. 102.5 Intimal product standard's requirements. 102.6 Moets the product standard's requirements. 102.8 Meets the product standard's requirements. 102.9 Fortection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 103 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 104 Clearances and creepage distances Meets the product standard's requirements. 105 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 106 Incorporation of wriching devices and components Does not apply, since the entire switchgear needs to be evaluated. 107 Internal electrical circuits and connections 108 Fortection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 109 Fortection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 109 Fortection against electric shock Someone of the product standard's responsib	Number of auxiliary contacts (change-over contacts)	0
Actuator color Actuator type Design verification Equipment heat dissipation, current-dependent Pvid Postign verification Equipment heat dissipation, current-dependent Pvid Postign verification Fact dissipation per pole, current-dependent Pvid Post dissipation, non-current-dependent Pvid Post dissipation, non-curren	Number of auxiliary contacts (normally closed contacts)	0
Actuator color Actuator type Design verification Equipment heat dissipation, current-dependent Pvid Actuator type Design verification Equipment heat dissipation, current-dependent Pvid 7.5 W Heat dissipation par pole, current-dependent Pvid 7.5 W Rated operational current for specified heat dissipation (In) 100 A Static heat dissipation nor pole, current-dependent Pvid 7.5 W Rated operational current for specified heat dissipation (In) 102.2 Corrosion resistance Meets the product standard's requirements. 102.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 102.3.2 Verification of resistance of insulating materials to normal heat 102.3.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects 102.4 Resistance to ultra-violet (IV) radiation 102.5 Lifting 102.6 Mechanical impact 102.6 Mechanical impact 102.7 Inscriptions Meets the product standard's requirements. 103.0 Des not apply, since the entire switchgear needs to be evaluated. 104.1 Clearances and creepage distances Meets the product standard's requirements. 104.1 Clearances and creepage distances Meets the product standard's requirements. Meets the product standard's requirements. 105.1 Fortection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 106.1 Incorporation of switching devices and components 107. Internal electrical circuits and connections Is the panel builder's responsibility, 108.2 Prower-frequency electric strength 109.3 Impulse withstand voltage Is the panel builder's responsibility, 109.4 Testing of enclosures made of insulating material Is the panel builder's responsibility, 109.5 Temperature rise The panel builder's responsibility, 109.6 Temperature rise The panel builder's responsibility, 109.6 Temperature rise calculation for the switchgear must be observed.	Number of auxiliary contacts (normally open contacts)	0
Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation apacity Pdiss OW Heat dissipation per pole, current-dependent Pvid 7.5 W Rated operational current for specified heat dissipation (In) 100 A Static heat dissipation, non-current-dependent Pvs 0W 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Series, of insul-mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violat (UV) radiation UV resistance only in connection with protective shield. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.2.9 Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.9 Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.9 Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.9 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.8 Incorporation of switching devices and components 10.9 Protection against electric alcricuits and connections 10.8 In the panel builder's responsibility. 10.9 Protection against electric alcricuits and connections 1	Actuator	
Design verification Equipment heat dissipation, current-dependent Pvid 7.5 W Heat dissipation capacity Pdiss 0W Heat dissipation capacity Pdiss 0W Rated operational current for specified heat dissipation (In) 100 A Static heat dissipation, non-current-dependent Pvid 0W 10.22 Corrosion resistance 0Weets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures 0Weets the product standard's requirements. 10.23.2 Verification of tresistance of insulating materials to normal heat 10.23.2 Verification of resistance of ultra-violet (UV) radiation 0W/ 10.24 Resistance to ultra-violet (UV) radiation 0W/ 10.25 Lifting 0Does not apply, since the entire switchgear needs to be evaluated. 10.26 Mechanical impact 0Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 0Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock 0Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 0Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections 1st he panel builder's responsibility. 10.9 Power-frequency electric strength 1st he panel builder's responsibility. 10.9 Power-frequency electric strength 1st he panel builder's responsibility. 10.9 Power-frequency electric strength 1st he panel builder's responsibility. 10.9 Power-frequency electric strength 1st he panel builder's responsibility. 10.10 Temperature rise 1st panel builder's responsibility. 10.11 Short-circuit rating 1st he panel builder's responsibility. 11.12 Electromagnetic compatibility 1st he panel builder's responsibility. 11.13 Heart-circuit rating 1st he panel builder's responsibility. 1st he specifications for the switchgear must be observed.	Actuator color	Black
Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss 0 W Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W Static heat dissipation, non-current-dependent Pvs 10.2.2 Strossion resistance Meets the product standard's requirements. UV resistance only in connection with protective shield. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. In Internal electrical circuits and connections Is the panel builder's responsibility. In Internal electrical circuits and connections Is the panel builder's responsibility. In Internal electrical circuits and connections In Internal electrical circuits and connection	Actuator type	Door coupling rotary drive
Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss 0 W Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvid Rated operational current for specified heat dissipation (In) 100 A Static heat dissipation, non-current-dependent Pvid 102.2 Corrosion resistance Meets the product standard's requirements. 102.2.3 I Verification of thermal stability of enclosures Meets the product standard's requirements. 102.2.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 102.3 Resistance to ultra-violet (UV) radiation 102.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 102.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 102.7 Inscriptions Meets the product standard's requirements. Meets the product standard's requirements. 103 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 104. Clearances and creepage distances Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 105. Frotection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 106. Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 107. Internal electrical circuits and connections Is the panel builder's responsibility. 108. Connections for external conductors Is the panel builder's responsibility. 109.4 Testing devices made of insulating material 109.4 Testing devices made of insulating material 109.5 Testing devices made of insulating material 109.6 Testing devices made of insulating material 109.6 Testing devices made of insulation. Eaton will provide heat dissipation data for the dev	Design verification	
Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid 7.5 W Rated operational current for specified heat dissipation (In) 100 A Static heat dissipation, non-current-dependent Pvs 0 W 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Internations 10.2.8 Dees not apply, since the entire switchgear needs to be evaluated. 10.2.9 Lifting 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Internal electrical circuits and connections 10.9 Internal electric strength 10.9 Connections for external conductors 10.9 Internal electrical circuits and connections 10.9 Internal electric strength 10.9 Internal electric circuits and connections 10.9 Internal electric divince and components 10.9 Inter		7.5 W
Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of tremal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.2.3.3 Resist. of insul. mat. to abnormal heatfire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9 Connections for external conductors Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating Short-circuit rating Short-circuit rating Short-circuit rating The panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections In the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 A Testing of enclosures made of insulating material 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
Static heat dissipation, non-current-dependent Pvs 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects 10.24 Resistance to ultra-violet (UV) radiation 10.25 Litting 10.25 Litting 10.26 Mechanical impact 10.27 Inscriptions 10.30 Begree of protection of assemblies 10.4 Clearances and creepage distances 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.4 Testing of enclosures made of insulating material 10.9.4 Testing of enclosures made of insulating material 10.11 Short-circuit rating 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 The pereit responsibility. 10.17 Internal electric strength 10.18 the panel builder's responsibility. 10.19 Interpare the entire switchgear needs to be evaluated. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Mechanical function 10.17 Mechanical function 10.18 Mechanical function 10.18 Mechanical function 10.19 The device meets the requirements. 10.10 Temperature, provided the information in the instruction		
10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Is the panel builder's responsibility. 10.9.1 Temperature rise 10.10 Temperature rise 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. 10.10 Temperature rise Meets the product standard's requirements. 10.2 Pose not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. 10.4 Is the panel builder's responsibility. 10.5 Protections for external conductors 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		0 W
10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Meets the product standard's requirements. Weets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. It is the panel builder's responsibility. The specifications for the switchgear must be observed. In the panel builder's responsibility. The specifications for the switchgear must be observed. In the device meets the requirements, provided the information in the instruction of the switchgear meets the observed.		Meets the product standard's requirements.
10.2.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. In the device meets the requirements, provided the information in the instruction.	10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.1 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Clearances and creepage distances Meets the product standard's requirements. 10.2 Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Is the panel builder's responsibility. 10.9.1 The panel builder's responsibility. 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Indicate the entire switchgear needs to be evaluated. 10.17 Indicate the entire switchgear meeds to be evaluated. 10.18 Mechanical function 10.19 Temperature rise the entire switchgear mich devices. 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Temperature fine entire switchgear meeds to be evaluated. 10.17 Indicate the entire switchgear needs to be evaluated. 10.18 Connections for equipments. 10.19 Temperature rise entire switchgear meeds to be evaluated. 10.19 Temperature rise entire switchgear function 1	10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.1 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Clearances and creepage distances Meets the product standard's requirements. 10.2 Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Is the panel builder's responsibility. 10.9.1 The panel builder's responsibility. 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Indicate the entire switchgear needs to be evaluated. 10.17 Indicate the entire switchgear meeds to be evaluated. 10.18 Mechanical function 10.19 Temperature rise the entire switchgear mich devices. 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Temperature fine entire switchgear meeds to be evaluated. 10.17 Indicate the entire switchgear needs to be evaluated. 10.18 Connections for equipments. 10.19 Temperature rise entire switchgear meeds to be evaluated. 10.19 Temperature rise entire switchgear function 1	10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements.
10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise The panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.4 Resistance to ultra-violet (UV) radiation	UV resistance only in connection with protective shield.
10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise The panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.27 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. In panel builder's responsibility. The specifications for the switchgear must be observed. In the panel builder's responsibility. The specifications for the switchgear must be observed.		
Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.1 The panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	·	· · · · · · · · · · · · · · · · · · ·
Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10 Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. The panel builder is responsibility. Is the panel builder is responsibility. Is the panel builder is responsibility. Is the panel builder is responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	· · · · · · · · · · · · · · · · · · ·	
10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. 10.15 be evaluated. 10.16 Incorporation of switching devices and components 10.17 Internal electric switchgear needs to be evaluated. 10.18 the panel builder's responsibility. 10.19 Is the panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		· · · · · · · · · · · · · · · · · · ·
10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 1s the panel builder's responsibility. 10.8 Connections for external conductors 1s the panel builder's responsibility. 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 1s the panel builder's responsibility. 1s the panel builder is responsibility. 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 1s the panel builder's responsibility. The specifications for the switchgear must be observed.		
10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Short-circuits and connections 10.15 the panel builder's responsibility. 10.16 the panel builder's responsibility. 10.17 The panel builder's responsibility. 10.18 the panel builder's responsibility. The specifications for the switchgear must be observed. 10.19 Mechanical function 10.19 Mechanical function 10.10 Temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.19 Streppend builder's responsibility. The specifications for the switchgear must be observed. 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 The device meets the requirements, provided the information in the instruction	•	
10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.18 the panel builder's responsibility. The specifications for the switchgear must be observed. 10.19 Mechanical function 10.10 Temperature rise calculation for the switchgear must be observed. 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.15 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.16 Temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.17 The panel builder's responsibility. The specifications for the switchgear must be observed. 10.19 The device meets the requirements, provided the information in the instruction		· · · · · · · · · · · · · · · · · · ·
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Is the panel builder's responsibility. 15 the panel builder's responsibility. 16 the panel builder's responsibility. The specifications for the switchgear must be observed. 17 the panel builder's responsibility. The specifications for the switchgear must be observed. 18 the panel builder's responsibility. The specifications for the switchgear must be observed. 19 the panel builder's responsibility. The specifications for the switchgear must be observed.		
10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Is the panel builder's responsibility. The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise The panel builder's responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
10.10 Temperature rise The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	·	· · · · · · · · · · · · · · · · · · ·
observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		The panel builder is responsible for the temperature rise calculation. Eaton will
observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.11 Short-circuit rating	
	10.12 Electromagnetic compatibility	, , , , ,
	10.13 Mechanical function	

Technical data ETIM 8.0

Low-voltage industrial components (EG000017) / Switch disconnector (EC000216)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Off-load switch, circuit breaker, control switch / Switch disconnector (ecl@ss10.0.1-27-37-14)	4-03
[AKF060013])	

[AKF060013])		
Version as main switch		Yes
Version as maintenance-/service switch		Yes
Version as safety switch		No
Version as emergency stop installation		No
Version as reversing switch		No
Number of switches		1
Max. rated operation voltage Ue AC	V	690
Rated operating voltage	V	690 - 690
Rated permanent current lu	Α	100
Rated permanent current at AC-23, 400 V	Α	100
Rated permanent current at AC-21, 400 V	Α	100
Rated operation power at AC-3, 400 V	kW	37
Rated short-time withstand current lcw	kA	2
Rated operation power at AC-23, 400 V	kW	55
Switching power at 400 V	kW	55
Conditioned rated short-circuit current Iq	kA	80
Number of poles		4
Number of auxiliary contacts as normally closed contact		0
Number of auxiliary contacts as normally open contact		0
Number of auxiliary contacts as change-over contact		0
Motor drive optional		No
Motor drive integrated		No
Voltage release optional		No
Device construction		Complete device in housing
Suitable for floor mounting		Yes
Suitable for front mounting 4-hole		No
Suitable for front mounting centre		No
Suitable for distribution board installation		No
Suitable for intermediate mounting		No
Colour control element		Black
Type of control element		Door coupling rotary drive
Interlockable		Yes
Type of electrical connection of main circuit		Screw connection
Degree of protection (IP), front side		IP65
Degree of protection (NEMA)		12